

SEDE

Via Martelli, 26 - 40138 Bologna
Tel. (051) 534015 - Fax. (051) 530085

CERTI.CER.

LABORATORIO DI ZONA

Via Valle d'Aosta, 1 - 41049 Sassuolo
Tel. e Fax. (0536) 802154

Part. IVA 0094778-0375

Bologna, 18/12/01

Spett. le
REX CERAMICHE ARTISTICHE
S.p.A.
Via Viazza, 30
41042 FIORANO MODENESE (MO)

TEST LABORATORY

TEST REPORT N° 4419/01

concerning ceramic tiles according to EN 87

Requested by:	REX CERAMICHE ARTISTICHE S.p.A. Via Viazza, 30 41042 FIORANO MODENESE (MO)
On (date):	11/12/01
For the sample marked:	"ROSA DEL DESERTO".

The results reported relate only to the samples tested.

No responsibility is taken for the accuracy of the sampling unless it is done under our own supervision.

The reproduction of this test report is only authorized in the form of a complete photographic facsimile. Our written approval is necessary for any partial reproduction.

This test report consists of 3 pages this cover included.



Consorzio universitario per la gestione del
«Centro di ricerca e sperimentazione per
l'industria ceramica»
D.P.R. 10-4-1978 n. 806
(G.U. 20-12-1978 n. 353)

Laboratorio autorizzato ad effettuare il
servizio di rilevamento dell'inquinamento
atmosferico.
Decreto MINISTERO SANITÀ 10-8-1974
(G.U. 14-9-1974 n. 240)

Laboratorio iscritto nell'elenco dei «Laboratori Esterni Pubblici
e Privati Altamente Qualificati».
Decreto MINISTERO RICERCA SCIENTIFICA 6-6-1983
(G.U. 6-7-1983 n. 183)

Membro ASTM
American Society for
Testing and Materials

Description of the sample:

Unglazed ceramic tiles 29,8 x 29,8 x 1,0 cm marked "ROSA DEL DESERTO".

Manufacturer: REX CERAMICHE ARTISTICHE S.p.A.

Sampling details:

- Where: -----
- Date: -----
- By whom: CUSTOMER
- How (methods): -----


DATE OF RECEIVAL IN LABORATORY: 11/12/01

TEST PERFORMED:

		Date of starting	Date of ending
<input checked="" type="checkbox"/>	EN 101 Determination of scratch hardness according to Mohs	18/12/01	18/12/01

EN 101 - Determination of scratch hardness of surface according to Mohs

Samples	1	2	3
Mohs hardness	6	6	6



DIRECTOR
Prof. Carlo Raimonari
CENTRO CERAMICO - BOLOGNA